



## Design Review Committee Driveway Apron Specifications

Where driveways intersect roadways, residents have the option of installing a 5' transitional apron between the roadway and their drive. The apron shall be Colorado Loveland Buff sandstone. The sandstone shall be a minimum of 2.5" thickness, laid either a random pattern or in a random coursed ashlar pattern on a 6" concrete slab, or 4" minimum for asphalt driveway with grouted joints struck flush. Drainage across the driveway, where required, should be integrated with the design of the apron. If a culvert is required by the Castle Pines Metropolitan District or installed for any reason, the outlet and inlet shall be terminated with the Loveland Buff sandstone or rhyolite headwall.

Driveways with no apron will be constructed such that the material of the driveway is continued to the roadway. All driveway modifications must be reviewed and approved by the Design Review Committee prior to installation. Contact the DRC Administrator at 303.814.1345 with questions.

